

**Response of
Wisconsin Power and Light Company
to
The Public Service Commission of Wisconsin
Data Request No. 1.01**

Docket Number:	05-CE-137
Date of Request:	January 29, 2009
Information Requested By:	Ken Detmer
Date Responded:	February 16, 2009
Author:	Jeffrey Knier
Author's Title:	Director, Clean Air Compliance Projects
Author's Telephone No.:	(608) 458-4866
Witness: (If other than Author)	

Data Request No. 1.01:

p. 3 par. 1: Refers to Edge 5 with a gross capacity of 380 MW. Should this read 380 MW net, not gross?

Response:

The subject statement in the Certificate of Authority is correct—380 MW represents the gross capacity for Edgewater Unit 5 based on the vendor *design* specifications (not the maximum capacity).